

APPLICATION No.: 22244

## TAP CLEARED

LOCATION: 10 Tobey Lane

OWNER: \_\_\_\_\_

31-313

MEASURES: 08/28/46

N X N Line of Tobey St

175.5 ft

E X W Line Morton Ave

8.3 ft

N X S Line House

10.1 ft

1" Copper Service 11/29/2017

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 65

Distance from main to curb stop (ft) 5.67

Distance curb stop to meter (ft) 16.33

Distance from curbface to curb stop (ft) 1.8

Depth of service (ft) 4.3

Total length of new pipe installed (ft) 22

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: no

Remarks: Needed to place 12" wrap by 1" corp on  
main. At corp there was pitting leaked by new corp

DATE

BEF.

AFT.

REMARKS

# METER HISTORY

# CHARGE OUTS

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST |  |  | REMARKS |
|------|---------|------|------|--------|---------|------|--|--|---------|
|      |         |      |      |        |         |      |  |  |         |
|      |         |      |      |        |         |      |  |  |         |
|      |         |      |      |        |         |      |  |  |         |
|      |         |      |      |        |         |      |  |  |         |
|      |         |      |      |        |         |      |  |  |         |

TOBEY LANE

