

39

APPLICATION No.: 22267

TAP CLEARED ✓

LOCATION: N.S. Ohio St. W. Condit st

OWNER: Raoul Sangeoin

MEASURES: 3/4 copper 11-27-1946
 W from W line Conduit 100.4 ft.
 S from N line Ohio 10.8 ft.
 E from E, line House 2.0 ft.
 Tap measurement
 E from E line house 8.9 ft.
 Laid with drain

 June 24, 1957 Repaired a leak in a 8" cement asbestos pipe by
 installing a Smith-Blair Saddle at a point 88.5 ft. W x W line
 Conduit St. - caused by the corporation slipping out of the main.
 1 8" DC-20-7E Smith-Blair Saddle, tapped 3/4", 9 5/8"
 3 ft. of 3/4" copper tubing 1 3/4" cop. to cop. coupling

NOTE: The corporation is now in line with the curb stop.

Oct 2, 1995: DPW WASTEWATER PULLED SERVICE

Renewed from main to a point 12ft Installed cop-cop at this
 point Stock: 12ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp
 1- 3/4 x 3/4 Fig 413 -----

[illegible]

CHARGE OUTS

[illegible]