

226

APPLICATION No.: 22270 3" Copper

TAP CLEARED

LOCATION: 274 Belleville Ave. (PIERCE MILL)

OWNER: Ace Holding Corp. DACO MFG. CO.

DATE

REF.

AFT.

REMARKS

MEASURES: 3" Copper Nov. 1, 1946  
 1-3" Darling tap gate; 3" wooden box frame  
 N from N line Nye 68.6 ft.  
 E from W line Belleville Ave. 14.0 ft.  
 S from N line Building 381.7 ft.

Dec. 14, 1977 Repaired leak by installing 2 repair sleeves:

4 ft. - 3" Copper tubing  
 2 - Smith Blair #226 Repair Sleeve 7 1/2" W

Measures of Sleeves: - - -

1st. - W x W line Bldg. 24 ft.  
 2nd - W x W line Bldg. 28 ft.

May 11, 1983 A 9 ft. piece of 3" copper was cut out & raised service to allow the 48" sewer to go by. Beginning 27 ft. W x W line Bldg. and heading west installed in this order:

3" 1/8 Bend  
 2.1 ft. of 3" Copper tubing  
 3" 1/8 Bend  
 6.4 ft. of 3" copper tubing  
 3" 1/8 Bend  
 2.1 ft. - 3" copper tubing  
 3" 1/8 Bend

This service has approx. 2.3' of cover and is wrapped in styrofoam. Contractor supplied by contractor.



N.A.

## CHARGE OUTS

[illegible]