APPLICATION No.: 22298	TAP CLEARED			
LOCATION: 502 S.S. Hillman, E. of Jenny Lind Street	DATE	BEF.	AFT.	REMARKS
OWNER: Edward T. Whitehead				
MEASURES: 3/4" E from Eline N from S line Heavy lead Jenny Lind St. Heavy lead 217.9 ft.				
W from E line House 2.9 ft. Laid with drain				
11/21/07 - Shut off 7 turn onn for repairs; Owner charged \$60.00 (Percy)				
6/23/08 - West End Water Main Rehab Contract # 4 - Perrina Const. Renewed water service from main to property line				
17 ft - 1" copper tubing; 1 - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop; 1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM				
			,	
		1		

METER HISTORY					CHARGE OUTS			
DATE	SET	SIZE	MAKE	NUMBER	READING	TEST	REMARKS	
6-11-47		3/	4 Empire AX	1415713				
					2.00			
-								

11
