

APPLICATION No.: 22344

TAP CLEARED

LOCATION: N.S. 1364 Stratford St., E x Acushnet Ave.

OWNER: Phillip Y. Cota

MEASURES:	3/4"	Copper	5-23-47
	E from E line	Acushnet Ave.	156.2 ft.
	S from N line	Stratford	7.0 ft.
	E from W line	House	7.3 ft.
	S from S line	House	30.1 ft.

May 13, 1970 Due to a cracked 6" cement asbestos main, it was necessary to install an Adams' repair sleeve see main pipe report - and a new corporation because the original one was damaged. 1 3/4" red head corporation Repaired in same trench as the main pipe leak.

[illegible]

## CHARGE OUTS

[illegible]