

APPLICATION No. 22410 10" C.I.

TAP CLEARED



LOCATION: N.S. Cove St. at head of Rd. Fr. (E) Blvd.

OWNER: Hathaway Mfg. Co.

DATE BEF. AFT. REMARKS

12/22/03 830 2003-520-0238

MEASURES: 10" C.I. Warrenspun 3/24/48
 1-8" Dar. Tap. Gate; 1-8 C.I. Gate Box 245#
 E from E line Cleveland 86.1 ft.
 N from S line Cove 29.6 ft.
 W from E line Bldg. 12.6 ft.
 FIRE SUPPLY

FIRE SUPPLY

Sept. 29, 1997
 Repaired leak on 10" fire supply. Installed
 5.5 ft. - 10" ductile pipe with 2 - 10" Rockwell #441 cast cplgs.

Measures of cplgs:
 1] N x S line Cove St. 36.0 ft.
 2] N x S line Cove St. 41.5 ft.

12/22/03 Repack gate stuffing box

[illegible]

CHARGE OUTS

[illegible]