

LOCATION: 289-291 Allen St.

OWNER: Leroy W. Wilber

MEASURES: 5/8" L lead Sept. 6, 1875

W 7/8 from Oak St. 30.7 ft.

S from N line Allen St. 6.8 ft.

E from W line house 11.6 ft.

April 25, 1974 Relocated this service from the 4" main to the new 10" main. The old 5/8" tap was abandoned in the 4" main. Tenewed from the 10" main to ~~inside cellar.~~ *PROP LINE*

36 ft. - 3/4" Copper tubing 3/4" Corporation

3/4" Curb stop Stop Box

1 lb. wiping solder

- - -

3/7/97 Per Gil Souto - Found lead coming into cellar.

This service may not have been renewed into cellar as appears above.

7/13/01 Measured by Souza, L. 8' punch. Informed owner lead inside. Renewal \$1,000. Owner will decide if she wants to renew or not.

11-15-01 Renewed from property line to inside cellar. (10ft. ins. prop. line) Stock: 10ft.-3/4" Copper tubing, 1-3/4" Curb Stop, 1-Caldwell Stop Box, 1-3/4"x3/4" cop to GADBURY & SONS, INC., COMP.

DATE

BEF.

AFT.

REMARKS

11-15-01

8:30

2001-460-5427

METER HISTORY

CHARGE OUTS

[illegible]