

APPLICATION No.: 22454

TAP CLEARED ✓

LOCATION: N.S. 611 Maxfield St., W x Beech St.

OWNER: Wallen Taylor

MEASURES: 3/4"

W from W line

S from N line

E from W line

Copper

Beech

Maxfield

House

9-4-47

68.3 ft.

6.5 ft.

10.2 ft.

8/26/08 - West End Water Main Rehab Contract # 4 - Perrina Const.

Renewed water service from main to a point 4 ft

4 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer

Inspected by Tim Ives, CDM

9/14/09 - City crew repaired 2 ft section of water service
damaged by NSTAR Gas

2 ft - 3/4" copper tubing; 1 Caldwell stop box

Foreman: Danny Perry

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]