

APPLICATION No.: 22611

## TAP CLEARED

LOCATION: S.S. 62 Sylvia St., W x River Rd.

DATE

BEF.

AFT.

REMARKS

OWNER: U. Bessette

4/3/97

971402581

## MEASURES:

3/4"

Copper

8-5-48

W from W line

River Rd.

321.5 ft.

N from S line

Sylvia

11.9 ft.

W from E line

Bldg.

6.0 ft.

4/3/97: tap reamed

Cement lined April 1977 - Could not get owner - house vacant - Boarded.

If this water is to be turned on - Tap must be reamed.

April 3, 1997 lead serv. replacement

REAMED TAP Stock: 1ft 3/4" copper tubing

1- 3/4 x 3/4 cop-cop cplg.comp

-----

[illegible]

# CHARGE OUTS