

APPLICATION No.: 22702

TAP CLEARED ✓

LOCATION: 402 Cottage St

OWNER: _____

31-313

MEASURES: 10/29/48

S from S line Smith 77.5 ft

W from E line Cottage St 6.0 ft

N from S line House 2.6 ft

House to be moved from 127 Kempton St. to here

1" Copper Service

03/24/2020 Lead Service Line Replacement Program

Phase 1 Contractor P Gioioso & Son

Type CU, Diameter (in)1, Water Pressure 55

Distance from main to curb stop (ft) 22

Distance curb stop to meter (ft) 19

Distance from curb face to curb stop (ft) 1.7

Depth of service (ft) 4.0

Total length of new pipe installed (ft) 26.5

Curb stop replaced: yes size 1"

Corporation replaced: no size 0.75"

Remark: 1-3/4" union installed where shown

DATE

BEF.

AFT.

REMARKS

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

