

#1531/1541

APPLICATION No.: 22715 - 6"

TAP CLEARED

LOCATION: W.S. Shawmut Ave., S of Plainville Rd.

DATE

BEF.

AFT.

REMARKS

OWNER: Massachusetts Air Industries AV FUEL/COLONIAL AIR

MEASURES: 6"

Oct. 20, 1948

N x Last Hyd., S x Plainville Rd.	19.4 ft.
E x W Line Shawmut Ave.	29.2 ft.
S x N line Bldg.	85.0 ft.

FIRE SUPPLY


Jan. 20, 24, 1984 Repaired break off 8" x 6" tapping sleeve by cutting in new 8" x 8" x 8" tee, 2 - 18" pc. of pipe, 2 - 8" S.B.#441 cplgs. on each side of main - north & south.

To service side: installed: 18" pc. - 8" C.I.C.L. Ductile pi
 8" Darling gate valve
 2.5 ft. - 8" C.I.C.L. Ductile pipe
 8" x 12" increaser, mech
 12" pc. - 12" C.I.C.L. Ductile pipe
 12" Smith Blair #441 cplg.
 Gate rodded back to tee

~~WRONG~~
~~DEM SER 22474~~ INACTIVE
 SER

no addn in computer

DEM SERU #022526A



[illegible]

CHARGE OUTS

56/58