

APPLICATION No.: 22770

TAP CLEARED ✓

LOCATION: S.E. Cor. 1148 Rockdale Ave. x Durfee St.

OWNER: James A McNaely

MEASURES: 3/4"

E from E line

N from S line

W from E line

Copper

Rockdale

Durfee

House

5-9-49

62.7 ft.

7.0 ft.

1.5 ft.

January 6, 1967 Leak at coupling flair on 1" copper, caused leak.

2 1/2 ft. of 3/4" copper tubing used.

1 3/4" cop. to cop. coupling

This was brought to our attention when the contractor was digging for the state D.P.W.. They were laying drain pipe. This leak was not caused by the contractor.

All digging and backfilling was done by the contractor. He will maintain street cuts.

[illegible]

CHARGE OUTS

[illegible]