

APPLICATION No.: 2278-bTAP CLEARED 8/12 - 4/6/99LOCATION: 37 So. SixthOWNER: Alexander MikusMEASURES: 1"

N from	Madison	111.0 ft.
E from W line	Sixth	7.4 ft.
S from N line $\frac{1}{2}$	House	2.5 ft.

9/9/78: Renewed 6" inside of curb stop to property line.

6 ft.- $\frac{3}{4}$ " copper; 2- $1\frac{1}{4}$ x 1" lead to cop. adapt. XXXS;

Caldwell stop box; Note: we did not put a new curb stop

because of the unusual large lead. If any work has to be done in the future, it should be from the main-in.-----

OCT 3 1979

Franklin renewed service from the main to the curb stop

9 ft.-1" copper

1-1" x 1" Fig. 413

1-1" curb stop 1-Caldwell stop box

3/28/89: Renewed from curb stop to prop line.

Stock: 10 ft.- 1" copper tubing. 1 - 1"x 1" cop to cop cplg., comp.

Note: Contractor had left 1 ft. of lead from property to 1 ft. outside.

[illegible]

CHARGE OUTS

[illegible]