| PARE DALE APPLICATION No.: 22882 | TAP CLEARED | | | |
|---|-------------|------|------|-------------|
| LOCATION: E.S. Rockdale Ave., N x Hathaway Blvd. | DATE | BEF. | AFT. | 1-8 REMARKS |
| OWNER: N.B. Housing Authority | | | | T 9203-1002 |
| MEASURES: 3" Copper 10-27049 | | | | |
| 1-3" Dar. Tap Gate; 1-4" C.I. Gate box 220# | | | | |
| E from W line ockdale Ave. 14.6 ft. N from N line Lexington 86.0 ft. | | | | |
| S from N line House 4-C E mide 32.6 ft. Rockdale Ave. | | | | |
| | | | | |
| Jan. 8, 1992 Service pulled while Gas Co. digging for gas leak. Repaired service by replacing 3" copper from a point 11 ft. E x | | | | |
| main to a point 16 ft. E x main with 2 - 3" SMith Blair #413 | | | | |
| transition cplgs. Stock: - 5 ft 3" Copper tubing | | | | |
| 2 - 3" Smith Blair #413 transition cplgs. | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| METER HISTORY | | | | | CHARGE OUTS | | | | | |
|---------------|--------------------|-------|---------|-----------|-------------|-------|------|--|---------|-------|
| DATE | DATE SET SIZE MAKE | SIZE | MAKE | NUMBER | READING | | TEST | | REMARKS | |
| | | Homen | | Nama Nama | | | | | | |
| 4-5-50 | | 3" | Trident | 8227376 | | | | | | A A A |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | - | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | 61291 | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | e de | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |