

APPLICATION No.: 23106

TAP CLEARED ✓

LOCATION: <sup>250</sup> S.S. Elm St. Ex Cottage

OWNER:

MEASURES:

F I S  
R E U  
P  
L  
Y

6" CI Warren spun Cement 6-21-50  
1-6" Dar. Tap. Gate; 1-6" C.I. Gatebox 232#

E from E line	Cottage	<del>150.0</del>	150.0
N from S line	Elm	<del>12.4</del>	11.6
E from W line	Bldg.	<del>20.6</del>	21.5
N x N line	Bldg.		11.6
Fire Supply			

Jan. 2, 1975 Renewed from the new 8" main on Elm St.  
to a point 3.5 ft. from the main.

8" x 8" x 6" C.I.C.L. Mech. Jt. Tee

2 ft. - 6" C.I.C.L. Class 2 Ductile pipe

6" Smith mech. jt. gate valve Buffalo gate box

6" Dresser cplg. style 138 located at a point 3.5 ft.  
from the main.

- - -

[illegible]

## CHARGE OUTS

[illegible]