

APPLICATION No.: 23183

TAP CLEARED ✓

LOCATION: S.S. 1164 Sassaquin Ave., E x Ash St.

OWNER: Joseph J Quail

MEASURES: 3/4" Copper 7-6-50  
W from W line Tobey 162.7 ft.  
N from S line Sassaquin Ave. 3.6 ft.  
E from E line House 1.4 ft.

April 4, 1975 Repaired this service by installing a  
new Hays tap.

1 - 3/4" Corporation. Broken by Fantoni

-----  
October 6, 1956 Renewed from meter box outside cellar to inside of  
cellar. meter relocated from meter box to inside of cellar.

30 ft. of 3/4" copper tubing

Stock supplied and installed by owner's plumber.

-----  
Dec. 17, 1975 Additional Measre

N from N line House 13.3 ft.

(onewest edge of Driveway)

-----  
-p-----

10/18/10 - City crew repaired tap leak - renewed water  
service from main to a point 1 ft

1 ft -3/4" copper tubing; 1 -3/4" cop to cop cplg comp;

1 -3/4" corporation tap; 1 -8" x 3/4" service saddle

Foreman: Danny Perry  
-----

DATE

BEF.

AFT.

REMARKS



[illegible]

## CHARGE OUTS

[illegible]