

APPLICATION No.: 2329

LOCATION: ~~27~~ Parker Cor. Homer

OWNER: Wm. A. Main

MEASURES: 3/4"

E from Cedar 99.6 ft.

S from N line Parker 6.7 ft.

E from W line body of house 5.4 ft.

Sept 2, 1997: Renewed from prop line to ins. cellar (10ft ins. prop line) Stock: 10ft 3/4" copper tubing
1- 3/4 x 3/4 cop-cop cplg.comp

== == == == == == ==

STREET RECONSTRUCTION

Aug 28, 1997: Renewed from main to prop line

Stock: 25ft 3/4" copper tubing 1-3/4" curb stop

1-caldwell stop box 1-3/4 x 1" & 1-3/4x5/8 lead-cop adapt xs

1- 3/4 x 3/4 Fig 413

䷗ ䷘ ䷙ ䷚ ䷛ ䷜ ䷝ ䷞ ䷟

5/13/10 - City crew reamed tap due to low pressure & replaced curb stop box that was offset

2 ft -3/4" copper tubing; 1 Caldwell stop box;

1 -3/4" x 3/4" Copper Fig. 413; Tap reamed - Renewed
service from main to a point 2 ft. Foreman: Frank Bento

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

9/2/97.

5-13-10

5-13-10

97.3600415.

2010-2008439

Tap reamed

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 2329

TAP CLEARED

LOCATION: Homer, N.W. Cor. 67 Parker St.

DATE

BEF.

AFT.

REMARKS

OWNER: _____

MEASURES: 3/4"

E from

S from N line

E from W line

L b ad

Cedar

Parker

body of house

10-28-1875

99.6 ft.

6.7 ft.

5.4 ft.

[illegible]

CHARGE OUTS

[illegible]