

APPLICATION No.: 23359

TAP CLEARED 8750-1016

LOCATION: 61 W.S.Rod.Fr. Blvd. (W) Sx Cove Rd.

OWNER: Stanley W. Sterling

MEASURES:

DATE

BEF.

AFT.

REMARKS

8753-0039

12/28/87

TAP REAMED

1-5-95

9501-01914

CLEAR ELECT.

3/4 "

Copper

Nov. 21, 1950

W from W line

Rod.Fr. Blvd.

91.0

S from N line

Grit

9.2

W from W line

Bldg.

11.3

12/8/87: Renewed from 20 ft. S x N line Grit St.

17 ft. S x N line Grit St. Stock: 1-3/4" curb stop

1 - 3/4x3/4 cop to cop cplg. 3ft. 3/4" copper tubing.

12/28/87: Renewed from main to prop line. Stock: 33 ft. 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box

1 - 3/4x3/4 cop to cop cplg. comp. 1-3/4x3/4 Fig.413

1/5/95: Renewed from lft in front of tap to the curb stop

Stock: 22ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp

1 ftin front of tap

NOTE: COPPER HAD A HOLE IN IT OUT IN STREET

+++++

[illegible]

CHARGE OUTS

[illegible]