

APPLICATION No.: 23399

TAP CLEARED ✓

LOCATION: E.S. 1534 Morton Ave. S x Leroy Ave.

OWNER:

MEASURES:	3/4"	Copper	3-22-51
	S from S line	Leroy	71.7 ft.
	W from E line	Morton Ave.	5.0 ft.
	S from N line	House	3.0 ft.

Aug. 1, 1957 Repaired this service by installing a 6" x 3/4" DC-20-7E Smith-Blair saddle 7 1/4" O.D. while the main pipe in Morton Ave. was being lowered.

Jan. 28, 1970 Relaid service from main to curb stop.
18 ft. - 3/4" Copper tubing - old copper left in ground.

February 3, 1975 Renewed from the main to a point 10 ft. from the main.
10 ft. - 3/4" Copper tubing 3/4" Corporation
3/4" x 3/4" Dresser cplg. - by Fantoni
Fantoni broke this service.

Jan. 22, 1977 Service frozen from the main to curb stop.
Main is 8" Transite - 2 1/2 ft. cover.

2/21/79: Frozen from main to curb stop.

[illegible]

CHARGE OUTS

[illegible]