

APPLICATION No.: 23456 3/4" Copper

TAP CLEARED

LOCATION: 14 Caswell St.

OWNER: William R. Omerod

MEASURES:	3/4"	Copper	Apr. 26, 1951
	E from E line	Caswell	41.7 ft.
	N from S line	Chicopee	11.8 ft.
	E from W line	House	7.0 ft.

April 22, 1968 Repaired leak in service. The 3/4" tap had become loose and a 8" x 3/4" Adams Service Slamp was installed and the tap was screwed in it.
1-8" x 3/4" Adams Servi-Seal Service Clamp.
1- 3/4" corp. tap. Red Head;

- - -

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

[illegible]