

APPLICATION No.: 23549

TAP CLEARED ✓

LOCATION: 3 Grove St.,

OWNER: Joao Henriques

MEASURES: 3/4" Copper Sept. 13, 1951

N from N line Grove St. 58.0 ft.

E from W line Orchard St. 7.8 ft.

S from N line House 2.3 ft.

9/20/88 Complaint of poor pressure - sprinkler heads do not  
pop up - not enough pressure.  
Checked Oct. 7, 1988 - Trouble inside.

Sept 12, 1995: poor pressure-cleared corp tap  
Renewed from main to a point 8 in Stock: 8 in. 3/4" copper  
tubing 1-3/4 x 3/4 cop-cop cplg.comp. 1-3/4x3/4 Fig 413  
=====

DATE BEF. AFT. 10/7 REMARKS

8840-5047

9/12/95

953702254

9/12/95: tap reamed

[illegible]

## CHARGE OUTS

[illegible]