

APPLICATION No.: 2370

LOCATION: 174 Grinnell St

## TAP CLEARED

OWNER:

31-313

1/14/2003 Ream

MEASURES:

December 13.1875

W X Crapo St

84.9 ft

N X S Line Grinnell St

6.1 ft

E X W Line House

7.6 ft

1" Copper Service

09/13/2018 Lead service line replacement program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 84

Distance from main to curb stop (ft) 7

Distance from curb stop to meter (ft) 18.2

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.5

Total length of new pipe installed (ft) 18.2

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes size 1"

Remarks: 1-3/4" union installed 1.0 lf  
outsdie curb stop

[illegible]