

APPLICATION No.: 23729

## TAP CLEARED

LOCATION: 77 Forest St.

OWNER: A. Roderick Gould

## MEASURES:

2" copper May 13, 1952  
~~1-2" gate valve Darling:~~ 1-4" C.I. Gate Box 220#  
 E from E line Bonney St. 197.5 ft.

S from N line Forest St. ~~23.0 ft.~~ 6.0 ft.

W from E line bldg. ~~8.2 ft.~~ 8.0 ft.

Replacing 5/8" service #16936.

E x W line bldg. 31.0 ft.

S x S line bldg. 9.6 f t.

July 12, 1989 Renewed from the newly installed 6" main to a point  
 1.2 ft. Removed 2" gate at main. Renewed from newly installed 2"  
 curb stop to a point 2 ft. inside sidewalk.

3.6 ft. - 2" copper tubing 2" curb stop

Gate box, compl. 2" corp. tap

6" x 2" serv. saddle 2" x 2" cop to cop cplg., comp. (2 ft. N x box)

-----

[illegible]