

LOCATION: 105 Caswell St.

OWNER: Federicks J. Reusch

MEASURES: 3/4"

N from N line	Copper	Sept. 26, 1952
E from W line	Maryland	18.0 ft.
N from S line	Caswell	8.9 ft.
	House	7.0 ft.

January 2, 1958 Repaired leak at tap by installing a  
Smith-Blair Repair Saddle for Serv. #23755  
1 - 8" x 3/4" Smith-Blair Saddle;

- - -

11/10/09 - City crew replaced water main from Appleton  
St to Maryland St. This service was reconnected to the  
new main

1 - 3/4" Corp Tap; 1 - 3/4" x 3/4" cop to cop cplg.  
Foreman: Danny Perry

-----

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]