

Mac Arthur Dr. 44 SOUTH ST. APPLICATION No.: 23917

LOCATION: E.S. 78-84 Prospect., S x South

OWNER:

MEASURES:

3" Copper Dec, 26, 1952  
S from S line South 120.0  
E from W line Prospect 15.8  
N from S line Bldg. 67.7

~~Oct. 15, 1980~~ Cold measure S x 1st hyd. S x South St. 55.3 ft.

April 1, 1968 Tapping valve & tapping sleeve removed.

A new 16" x 16" x 8" Tee, 8" Gate Valve, A.B.,  
37.5 ft. - 8" Pipe with a C.I. plug with adaptor to  
receive 3" copper service. Installed by Contractor.  
1st bend 23 ft. W x bldg.  
2nd bend 27 ft. W x bldg.

Oct. 23, 1980 This service was not up to the property  
line.

Contractor picked it up at a point 57 ft. W x E line  
Bldg. & installed an 8" x 6" Reducer:

Measures of 8" x 6" Reducer

S x S line South St. 99.0 ft.

W x E line Bldg. 57.0 ft.

Installed 6" C.I.C.L. Pipe into the property with a 6"  
Gate Valve. Service # 29875 - 1" was tapped into this 6"  
service at a point 50 ft. W x E line of Bldg.

TAP CLEARED

DATE BEF. AFT. REMARKS

FIRE SUPPLY as of 10/23/80



[illegible]

## CHARGE OUTS

[illegible]

MAC ARTHUR DR.

GAS PIPE OVER  
ELEC. DUCT

8" x 6" REDUCER

8" EXISTING SERVICE

6" DUCTILE PIPE

99 FT.

6" GATE INSIDE  
P.L.

BOUNDSTONE

57 FT.

50 FT.

# 29875-1"

# 23917

SOUTH ST.