

APPLICATION No.: 24022

TAP CLEARED

LOCATION: W.S. 1521 Padanaram Ave. S x Cove Rd.

OWNER: ~~Frederick H Worster~~

MEASURES:

3/4"

Copper

5-29-53

S from S line

Cove Rd.

379.8 ft.

E from W line

Padanaram Ave.

~~9.0 ft.~~

6.0

S from N line

House

1.3 ft.

 January 19, 1965 Due to th 8" C.I. main pipe being cracked near
 the corporation for this service it was necessary to ^{replace} this
 corporation; This corporation was relocated $1\frac{1}{2}$ ft. northerly.
 Renewed from main to 3 ft. from main.

3 ft. of 3/4" copper tubing 1 3/4" corporation

1 3/4" cop. to cop. cplg. A-1525

50. 1955

March 24, 1982 Tied into new 8" main.

1 - 3/4" Corporation

3 ft. - 3/4" Copper tubing

1 - 3/4" cop to cop cplg.

SEP 16 1982 --Relocated curb stop 3 ft. West. 1-3/4" curb
 stop/ stop box; Pavao working there. Cut in new Stop &
 left old one in place.

9-6-89 NOT READING - KAREN

[illegible]