

APPLICATION No.: 24066---3<sup>ff</sup>

# TAP CLEARED

LOCATION: E.S. 2836 Acushnet Ave., N x Glen St.

OWNER: Mary J. Frates

MEASURES: 3" Copper July 6, 1953  
N from S line Glen 15.3 ft.  
E from E line Acush.Ave. 1.4 ft.  
1-3" Dar. Tap Gate Valve; 1-4" C.I. Gatebox #220  
Replaces 2" C.I. Ser. #16869.  
2" Meter.

2/14/86 shut off at gate

Dec. 27, 1994 Poor Pressure. Removed tapping gate & cleaned tapping sleeve & gate. Full pressure has been restored.

Stock:

1 - 3" Smith Blair #413 transition cplg. 3.13 OD  
located 1½ ft. N x service gate.

1 - #10 Gate Box, compl.

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

BEF.

AFT.

REMARKS

reading 8/12/83  
Proc

12-23-94

9451-03492

## METER HISTORY

## CHARGE OUTS

[illegible]