

16 APPLICATION No.: 24174  
LOCATION: S.S. Exeter St.,, E x Commonwealth Ave

OWNER: Raymond L. Silva

MEASURES: 3/4" Copper Nov. 27, 1953

W from W line Brownell Ave. 157.2  
N from S line Exeter 8.3  
E from W line House 4.9

Sept. 12, 1988 checked pressure - problem is on faucet screen. REzendes

3/8/91 Took color sample clear Bento

TAP CLEARED

DATE BEF. AFT. REMARKS

[illegible]

## CHARGE OUTS