APPLICATION No.: 2420	TAP CLEARED			
LOCATION: 203 Purchase St	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES: March 31,1876 S X South St E X W Line Purchase St S X N Line House 11/01/2018 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 100 Distance from main to curb stop (Ft) 8 Distance from curb stop to meter (ft) 19.8 Distance from curb stop to curb face (ft) 1.7 Depth of service (ft) 4.3 Total length of new pipe installed (ft) 27.8 Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: Yes size 1"				