

APPLICATION No.: 24295

TAP CLEARED

LOCATION: W.S. 327 Shawmut Ave., N x Tilton

OWNER: N.B. School Dept

DATE _____

BEF.

AFT.

REMARKS

8/30/92

963506279

MEASURES:	3"	Copper	6-23-8-54
	1-3" D ^a r. Tap Gate Valve; 1-4" C.I. Gatebox	220#	
	N from N line	Maitland	67.5 ft.
	E from W line	Shawmut Ave.	13.2 ft.
	N from S line	Bldg.	9.5 ft.
	Replaces 2" C.I. 9778 to be discontinued.		

August 30, 1996 Repaired 3" broken gate spindle. Broken by overturning.

Stock: New spindle 6 - 3 1/2" x 1/2" bolts & nuts

4 - 3" x 3/8" bolts & nuts 2 gaskets

1 - #10 Gate Box, compl.

[illegible]

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. A vertical line runs down the left side, and a horizontal line runs across the middle, possibly indicating where the page was bound or folded. There is a small, faint red mark near the center of the page.

APPLICATION No.: 9778

TAP CLEARED

LOCATION: 135 Shawmut Ave.

OWNER: N.B. School House

MEASURES: 2"

N from	Maitland	89.0 ft.
E from W line	Shawmut Ave.	8.8 ft.
N from S line	Bldg.	33.0 ft.

Service discontinued - #9778 - 2" CI to the HA Kempton School was shut off at the 2" gate valve

Now supplied by #24295 - 3" copper

[illegible]

CHARGE OUTS

[illegible]