

LOCATION: 1127 Braley Rd.

OWNER: Guy Rook

MEASURES: 3/4"

W from W line

S from N line

W from E line

Copper

Acushnet Ave.

Braley Rd.

House

May 9, 1955

1226.6 ft.

6.0 ft.

22.1 ft.

July 26, 1963 Relocated stop box due to widening
of Braley Rd.

7½ ft. - 3/4" copper tubing; 1-3/4" cop to cop cplg. fig
415; Stop box is now S x N line Braley Rd. 3.0 ft.

- - -

Sept. 16, 1963 Renewed from 8 ft. outside curb stop
to a point 14½ ft. outside curb stop.

6½ ft. - 3/4" copper tubing; 2 - 3/4" cop to cop cplg.
A-1525.

- - -

Sept. 30, 1963 Renewed from 15 ft. outside curb stop
to 16 ft. outside curb stop.

1 ft. - 3/4" copper tubing; 2 3/4" copper cplg., A-1525;

- - -

Dec. 16, 1969 Renewed from the main to a point 22 ft.
from the main. This leak was caused by the St. Dept.
while they were installing a new main sewer on Braley
Rd.

22 ft. - 3/4" copper tubing; 1-3/4" cop to cop cplg.

- - -

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

[illegible]