

APPLICATION No.: 24431

TAP CLEARED

LOCATION: S.E. cor. 908 - 912 Purchase & Middle St.

DATE

BEF.

AFT.

REMARKS

OWNER:

MEASURES: 3"

COPPER

1-24&25-55

Measures of 4" Gate Valve installed 8/27/84

E x E line Purchase St.

45.0 ft.

N x S line Middle St.

4.0 ft.

(new south line)

NOTE: Old gate & gate box left in place they will
be on private property.Aug. 27, 1984 Renewed from new 8" Middle St. main & tied
into existing 3" service.

8" x 8" x 4" Teem mech.

3.5 ft. - 4" CICAL Ductile pipe

4" Gate Valve, mech.

1 - Gate Box, complete

6.1 ft. - 4" CICAL Ductile Pipe

4" x 3" Reducer where tie in was made with 4" transition cplg.

Gate rodged north to tee & tee truss blocked.

2/14/12 - City crew replaced curb stop box, due to tree
roots

1 - #10 gate box

Foreman: Frank Bento

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 24431

TAP CLEARED

LOCATION: S.E. Cor. 908-12 Purchase & Middle Sts.OWNER: Charles Eliás

MEASURES: 3"

	Copper	1-24&25-55
1-3" Dar. Tap Gate Valve; 1-4" C.I. Gatebox 220#		
E from E line	Purchase	45.0 ft. 44.8
N from S line	Middle	13.8 ft. 12.0
EW from E line	Bldg.	50.0 ft.
N x N line	Bldg.	12.0 ft.

NOTE: This gate left in
place - it will be on
private property.

A sketch of this service is on the Middle St. main
report.

Feb. 26, 75 Renewed from the new 8" main in Middle
St. to a point 4 ft. from the main.

8" x 8" x 4" C.I.C.L. Class 250 Tee, M.J.

4" x 3" C.I.C.L. Class 250 reducer, M.J. Spigot & Bell

1.6 ft. - 3" C.I.C.L. pipe

3" Smith private gate valve, M.J.

Buffalo Gate Box

3" Brass caulking conn.

May 14 & 16, 1955 Replaced cracked 8" x 8" x 3"

A.P. Smith tapping sleeve

8" x 8" x 3" Tapping sleeves

2 - 8" lead joints 29½ lb.s

[illegible]

CHARGE OUTS.

[illegible]