

APPLICATION No.: 24440

LOCATION: N.W. Cor. 1191 Purchase & Maxfield Sts.

OWNER: N B Textiel Inst.

MEASURES:	2"	Copper	3-11-55
	1-2" Gate Valve; Darling all bell		
	W from W line	Purchase N	45.1 ft.
	S from NNline	Maxfield	6.1 ft
	E from W line	Bldg	18.8 ft.
	Replaces old 2" C.I. Ser. 19127		

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS



[illegible]

CHARGE OUTS

[illegible]

1171 in computer

APPLICATION No.: 24440

TAP CLEARED

LOCATION: N.W. Cor. 1191 Purchase & Maxfield St.

OWNER: N.B. Textile Institute

MEASURES:	2"	Copper	3-11-55
	1-2" Darling Gate Valve, all bell		
	W from W line	Purchase N	45.1 ft.
	S from N line	Maxfield	6.1 ft.
	E from W line	Bldg.	18.8 ft.
	Replaces old 2" C.I. Ser. #19127		

7/12/05 Repaired 2" gate valve..broken in "off" position. Stock:
1 - 6" 441 (capped fire supply in s/w #19126); 1 - 2" curb stop;
1 - 2" x 2" copper - copper; 4 ft. 2" copper; gate box;
Domestic water located in the same place as before. Insp: Grenon

[illegible]

CHARGE OUTS

[illegible]