

APPLICATION No. 2400 570

TAP CLEARED

83-16-018

LOCATION: 144 Cedar St.

OWNER: John W. Matthews

MEASURES: 5/8"

N from	Hillman	88.0 ft.
W from E line	Cedar	6.6 ft.
N from S line	House	6.6 ft.

11/16/79: Renewed from main to a point 1.5 ft. from main.
 1.5 ft.-3/4" copper; 5/8" x 3/4" lead-cop. adapt. XS;
 Tail piece cplg. - - - -

APR 19 1983 --Renewed from 6" outside curbstop to the cellar.
 12.5 ft.-3/4" copper (5 ft. inside); 3/4" curb stop;
 stop box; 5/8" x 3/4" lead-cop. adapt. XS;
 - - - -

12/28/88: Renewed from main to a point 3.6 ft. used samed cop adapt.
 Stock: 3.6 ft. 3/4" copper tubing 1-1/2"x3/4" Fig.413-flared
 =====

12-3-99 Renewed from main to inside cellar. Stock:
 27 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 -1/2"
 x 3/4" Fig. 413.

DATE

BEF.

AFT.

REMARKS



T8907 23

12-3-99 1999490271P

12-3-99 Tap reamed

METER HISTORY

CHARGE OUTS

[illegible]