

APPLICATION No.: 2481

TAP CLEARED 8232-0910

LOCATION: 154-56 Mill Cor. Cottage

OWNER: Wm Henwood

MEASURES: 3/4"

S from	Mill	46.2
W from E line	Cottage	6.4
N from S line	House	2.1

Oct. 8, 1965 Renewed from main to 5 ft. inside curb stop  
 28 ft. - 3/4" Copper tubing 3/4" copper cplg.  
 3/4" reused corp. cplg. 3/4" cop to cop stop  
 1# wiping solder

Sept. 18, 1974 Renewed from the new 8" main in Cottage  
 St. to a point 1 ft. inside property line.  
 27 ft. - 3/4" Copper tubing 3/4" McDonald Tap  
 3/4" Mueller curb stop 5/8" x 3/4" Ford lead -  
 Caldwell Stop Box cop. adaptorXS  
 (1 ft. inside prop. line)

Measures of new 3/4" curb stop:

S x S line Mill St.	45.0 ft.
W x E line Cottage St.	6.5 ft.
N x S line House	1.9 ft.
W x W line House	6.5 ft.

AUG 12 1982 -- Renewed from curbstop to inside cellar.  
 Leak inside cellar wall. 9.0 ft. - 3/4" copper; same curb stop;

[illegible]

## CHARGE OUTS

[illegible]