

APPLICATION No.: 24845

TAP CLEARED ✓

LOCATION: 108 E.S. Shirley St., N x PitmanOWNER: William Botelho

MEASURES:	1"	Copper	5-23-56
	N from N line	Pitman	103.2 ft.
	W from E line	Shirley	8.1 ft.
	N from S line	House	2.4 ft.

November 13, 1956 Repaired a leak by installing a DC-20-7E Repair
Saddle for Service #24845

1 6" DC-20-7E Smith-Blair Saddle, tapped 1" Mueller thread

12-14-99 Renewed from a point 1 1/2' outside curb stop
to a point 4 1/2 ft. outside. Stock: 3 ft. - 1" Copper
tubing, 1 - 1" Curb Stop, (@4 1/2' outside C.S.) used as
cop-cop, 1 - 1" x 1" cop to cop cplg., comp.

[illegible]

CHARGE OUTS

[illegible]