

APPLICATION No.: 24900

TAP CLEARED ✓

LOCATION: N.S. 1007 Monmouth S. W x Acushnet Ave.OWNER: Paul A Dushaine

MEASURES: 2" Copper 8-3-56

1-2" D ar. Gate Valve, all bell; 1 R1144 Caldwell  
Gatebox

N from N line Monmouth 89.5 ft.

E from W line Acushnet Ave. 8.6 ft.

N from N line House 3.8 ft.

Service to replace 3/4" Ser. 22543

11/9/81: Replaced broken 2" Cast Iron Gate & installed  
2" curb stop also 2.0 ft. of 2" copper inside of stop.  
Closed 2" tap to make repair. 2.0 ft.-2" copper; 2" curb  
stop Ford; Same stop box; 2" x 2" cop.-cop. comp. cplg.

- - - - -

[illegible]

## CHARGE OUTS

[illegible]

APPLICATION No.: 22543

TAP CLEARED

LOCATION: N.W. Cor. 1007 Monmouth St., x Acushnet Ave.

OWNER: Ferninand Belangef

MEASURES: 3/4"

N from N line  
E from W line  
N from S lineCopper  
Monmouth  
Acushnet Ave.  
House4-29-48  
35.3 ft.  
8.3 ft.  
20.9 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]