

APPLICATION No.: 25015---3/4"

TAP CLEARED

LOCATION: S.E. Cor. 312 1/2 Acushnet Ave., & Peckham Lane

OWNER: Mrs. Jeannette Valors

DATE

BEF.

AFT.

REMARKS

12/9/88: TAP REAMED

8849-4265

MEASURES: 3/4" Copper Oct. 10, 1956
 N from N line Fox 157.2 ft.
 W from E line Acushnet Ave. 5.3 ft.

12/9/88: Renewed from main to a point 6 ft.

Stock; 6ft. 3/4" copper tubing 1-3/4x3/4 cop to cop cplg
 comp. 6 ft. from tap 1-3/4x3/4 Fig. 413

=====

4/8/07 POOR PRESSURE KITCHEN TAPSET ONLY. TOLD HER
 TO CALL TUNBER. OWNER NOTED CITY CREW
 11/3/01/15 MAIN LAST YEAR DID REPAIR TO
 SERVICE TAP TO SHUT HER WATER OFF FOR
 REPAIRS - NO RECORD OF WORK DONE...

6/7/07 N.E. Pressure Project .. tied service into new 12" main
 Stock: 2 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop cplg.; 3/4"
 corp tap Foreman: D Monty

TAP CLEARED

APPLICATION No. 1

LOCATION:

OWNER: _____

[illegible]