

APPLICATION No.: 25015---3/4"

TAP CLEARED

LOCATION: S.E. Cor. 3124 Acushnet Ave., &amp; Peckham Lane

OWNER: Mrs. Jeannette Valors

DATE BEF. AFT. REMARKS

12/9/88: TAP REAMED 8849-4265

MEASURES: 3/4" Copper Oct. 10, 1956  
 N from N line Fox 157.2 ft.  
 W from E line Acushnet Ave. 5.3 ft.

12/9/88: Renewed from main to a point 6 ft.  
 Stock; 6ft. 3/4" copper tubing 1-3/4x3/4 cop to cop cplg  
 comp. 6 ft. from tap 1-3/4x3/4 Fig. 413

=====

4/16/07 POOR PRESSURE KITCHEN FOUNTAIN ONLY. TOLD HER  
 TO CALL PLUMBER. OWNER NOTED CITY CREW  
 1957-1986 MAIN LAST YEAR DID REPAIR TO  
 SERVICE HAD TO SHUT HER WATER OFF FOR  
 REPAIRS - NO RECORD OF WORK DONE...

6/7/07 N.E. Pressure Project .. tied service into new 12" main  
 Stock: 2 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop cplg.; 3/4"  
 corp tap Foreman: D Monty

-----

