

159 ROWE ST.

APPLICATION No.: 25106

TAP CLEARED

LOCATION: S.W. cor. Sawyer St., & Rowe St.

DATE

BEF.

AFT.

REMARKS

OWNER:

MEASURES: 1" Copper 6-11-57

W x W line Rowe 44.8 ft.

N x S line Sawyer St. 8.1 ft.

W x W line house 8.0 ft.

W x E line house 32.6 ft.

N x N line house 39.0 ft.

October 10, 1986 Smith Cont. installed from property line to cellar.

36 ft. - 1" Copper tubing

1" copper to copper cplg.: 3 ft. S x stop box.

Oct 30, 1996: Leak was at tap

Tap was loose in 8" transite main Had to put service saddle on with new tap. Stock: 1ft 1" copper tubing 1-1"x1" cop-cop cplg.

comp 1ft outside of tap 1-1" corporation tap 1-8"x1" bronze service saddle

=====

[illegible]

CHARGE OUTS

[illegible]