

APPLICATION No.: 25134

TAP CLEARED

LOCATION: E.S. Drive, Opposite Irvington St. (1911 Acushnet Ave)

OWNER: Wilks Library

MEASURES:	2"	Copper	7-24-57
	1-2"	Darling Gate Valve	
	1-4"	C.I. Gate Box complete	
	E from W line	Irvington Court	16.7 ft.
	N from S line	Irvington St.	14.2 ft.
	N from S line	Library Bldg.	47.2 ft.

April 27, 1995

Service broken by DPW while digging for sewer.
Repaired with 11 ft. - 2" Copper tubing
2 - 2" x 2" cop to cop cplg., compression
Measures of cplgs.:

1]	W x E line	Irvington Ct.	18.0 ft.
	S x N line	Irvington St.	9.0 ft.
2]	W x E line	Irvington Ct.	25.0 ft.
	S x N line	Irvington St.	16.0 ft.

1/18/08 - Install new 2" curb stop on 2" copper service

New Measures:

S X Hydrant	19.0
E x Hydrant	5.0
E x 8" gate valve(line)	19.6

METER HISTORY

CHARGE OUTS

[illegible]