

APPLICATION No.: 2519

TAP CLEARED

LOCATION: 58-60 Spruce

OWNER: A Ricard

MEASURES: 3/4 5/8 tap

N from	Maxfield	144.2 ft.
W from E line	Spruce	6.5 ft.
S from N line	House	7.0 ft.

-----  
 May 20, 1949 Replaced lead pipe with 3/4" copper tubing from tap to inside the cellar.

33 ft. 6 inches of copper tubing 1 3/4" cop. to cop. stop  
 1 3/4" copper to 3/4" I/ P. Female coupling  
 -----

~~January 11, 1961 Renewed from 5 ft. outside curb stop to 1 1/2 ft. inside curb stop.~~

~~6 1/2 ft. of 3/4" copper tubing 1 3/4" dresser cplg. style 88  
 1 3/4" copper stop 2 lbs. wiping solder  
 -----~~

*Ground water going in cellar Openshaw 8/9/89  
 1 ft of clean water in cellar Duarte 11/8/89.*

6/14/05 Replaced curb stop box only....Bento  
 -----

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]