

APPLICATION No.: 25201

LOCATION: 136 Lafayette St., N x Carlisle St.

OWNER: \_\_\_\_\_

MEASURES: 1"

N from N line

W from E line

S from N line

Copper

Carlisle

Lafayette

House

7-8-57

229.2 ft.

8.0 ft.

3.8 ft.

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

8/11/04 830 am 2004-330 5185

8/11/04 Repaired broken 6" sewer service. Stock: 6" PVC pipe - 6 ft;  
6" x 8" saddle; 6" - 22° bend; 6" cplg; 5 ft. 8" PVC (main sewer);  
8" cplg. PVC-clay; 1 PVC-PVC cplg;  
Repaired 10" drain main using: 3 ft. x 10" PVC; 2 cplgs. PVC-clay.  
Repaired water service by replacing with: 8 ft. 1" copper tubing;  
2 - 1" x 1" cop-cop cplgs. over drain & sewer mains  
-----

[illegible]

## CHARGE OUTS

[illegible]