

APPLICATION No.: 25206 2nd Copper

TAP CLEARED

1 CAPE ST. APPLICATION No.: 25206
LOCATION: N.S.Howland (20' Right of Way) E x Cape St.

OWNER: Harbor Development Corp.

MEASURES:	2"	Copper	July 8-9, 1957
	1-2" Darling Gate Valve	1-4" C.I. Gate Box	
	E from E line	Cape	533.7 ft. ?
	S from N line	Howland (20')	10.8 ft.
	E from W line	Meter Box	1.8 ft.

3/6/91 Additional Measures:

Directly west in line with hyd. gate 8.0 ft.
N x curb 4.5 ft.
E x Cape S t. 44.0 ft.

No meter in pitt - now in bldg. 7/26/73 JR

Northend Const. repaired leak inside meter pit by cutting out the copper & cplgs. Installed 10 ft. - 2" copper tubing &

2 - 2" x 2" cop to cop cplg., compression.

Bento

EX GATE VALVE CAPR ST CUL DE SAC 76.0'
W X W LINE BLDG #26 GREEN & WOOD PIER 210.0'

METER HISTORY

CHARGE OUTS

[illegible]