

APPLICATION No.: 25234 1" Copper

TAP CLEARED

LOCATION: 405 Bartlett St.

OWNER: Angosthino Touveia

MEASURES: 1" Copper Sept. 19, 1957  
S from S line Westland 196.2 ft.  
E from W line Bartlett 8.0 ft.  
S from N line House 16.2 ft.  
Main is 18 ft. E x W line.

March 26, 1958 Repaired leak at tap; renewed from  
main to a point  $\frac{1}{2}$  ft. from main.

1 - 8" x 1" DC-20-7E Smith-Blair Saddle.

12 ft. - 1" copper tubing type K, soft; 1-1" x 1" cop.  
cplg., A-1552

- - -

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]