

[illegible]

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

OWNER: John Alves

MEASURES:

3/4"	Copper	11-6 57
E from E line	Jenny Lind	230.8 ft.
N from S line	Roger	2.1 ft.
E from W line	House	2.1 ft.
Main is 14 ft. N x S line.		

6/13/08 - West End Water Main Rehab Contract # 4 - Perrina Const  
Renewed water service from main to a point 5 ft  
5 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer  
Inspected by Tim Ives, CDM

[illegible]

## CHARGE OUTS

[illegible]