APPLICATION No.: 25333	TAP CLEARED				
LOCATION: N.S. Seymour St. E x Fort	DATE	BEF.	AFT.	REMARKS	
OWNER: Wilford Cadieux					
MEASURES: 3/4" Copper 2-6-58 E from E line Fort 182.9 ft. S from N line Seymour 5.0 ft. E from W line House 11.0 ft. Main is 31 ft. S x N line.					
Aug 12,1997: Renewed from main to a point 12ft Stock: 12ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg comp installed 12ft north of main 1-3/4" corporation tap 1-3/4 x 6 service saddle bronze double strap ====== 9/24/03 Renewed from newly installed 8" main to a point 2 ft. Stock: 2 ft. 3/4" copper tubing; 3/4" x 3/4"	t				
cop-cop cplg., comp.; 3/4" corp tap					

METER HISTORY								CHARGE OUTS		
DATE	SET	SIZE	MAKE	NUMBER	READING	-	TEST		REMARKS	
1-30-59			Hersey F	613323						- And Control of the
		- 14								
								-		
										47.24
						-				
										No real March Land Spring 413