

APPLICATION No.: 2535

TAP CLEARED 8841-3759

LOCATION: 101 Sycamore

OWNER: John E Ashworth

MEASURES: W from Spruce 22.2 ft.  
 S from N line Sycamore 6.9 ft.  
 E from W line House 12.0 ft.

June 4, 1975 Renewed from the main to a point 1.5 ft.  
 from the main.

1½ ft. - 3/4" Copper tubing 3/4" x 3/4" Fig. 413  
 5/8" x 3/4" lead connector

May 10, 1976 Renewed from the main to a point 4½ ft.  
 inside main.

4½ ft. - 3/4" Copper tubing  
 5/8" x 3/4" lead to copper adaptor

NOTE: Cellar had 1 ft. of water.

June 2, 1977: Renewed from 6" outside curbstop to 2 ft. inside.  
 2½ ft. - 3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to copper  
 adapt. XXS; Caldwell stop box;

3/10/79: Renewed from main to curb stop 24 ft. - 3/4" copper;  
 3/4" curb stop

10/12/85: Renewed from curb stop to ins. cellar. (6ft. ins. prop  
 line) Stock: 13ft. 3/4" copper tubing 1-Caldwell stop box.

=====

DATE

BEF.

AFT.

REMARKS

curb stop. Cellar had a good  
 2 ft. of water. Fireman  
 pumped it out. Also drain  
 trouble. Called D.P.W.

[illegible]

## CHARGE OUTS

[illegible]