

APPLICATION No.: 25423

TAP CLEARED

LOCATION: 32 Hudson St.OWNER: John A. GrotonMEASURES: 3/4" Copper Sept. 22, 1958W from W line Rod. Fr. Blvd. (E) 329.1 ft.N from S line Hudson St. 5.8 ft.E from W line House 11.2 ft.

May 27, 1991 After repairing a main pipe break - water turned on
main - this tap blew out (no saddle on transite)

Renewed from main to a point 1.0 f t. from main.

1.0 f t. - 3/4" copper tubing 1 - 3/4" x 3/4" cop to cop cplg., comp.

1 - 3/4" corp. tap 1 - 6" x 3/4" service saddle

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]