

APPLICATION No.: 25474
LOCATION: E.S. Rod. Fr. Blvd. (E), N. Momkey Island N.B. Park Dept.
OWNER: ES NINA ST
MEASURES:

NOT READING 8/27/2009

4" Cem. Asbestos Nov. 7th 1958
4" Dar. Tap Gate; 1-4" C.I. Gatebox 209#

	S from S line	(wall)	Poor Farm Lane	49.0
	E from Wline	(wall)	Rd.Fr.Bld.(E)	25.0
	W from E line	(wall)	Rd.Fr. Bld.(E)	61.5
END OF	Ex W face of wall on East		Sides St.	10.5
SERVICE	N x S opening in wall.			

May 27, 1966 Removed service #25474 - 4" and installed 8" cast iron split sleeve.

Stock Removed:

1 4" C.I. gate box, complete - 224 lbs.

1 4" Darling tapping gate - reg. stuff. box

1 8" x 4" tapping sleeve

Stock installed:

1 8" cast iron split sleeve, 12 in. long

10 lbs. Mineralead - 3/4" Braided Jute

Measures of 8" split sleeve:

S x S line (wall) Poor Farm Lane 49.0

E x W line (wall) E. Rod. Fr. Blvd. 25.0

N x N line Portland St. 362.7

[illegible]

CHARGE OUTS

[illegible]